

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-220579

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Smoke Detector Alarm

(refer to attached appendix for details and conditions)

Placed on the market Shenzhen Pilot Guards Safety Technology Co. Limited

under the name or trade mark of: No.9, Huafu Industrial Park, Huachang Road

Longhua District, Shenzhen City, Guangdong Province

P. R. China

PGST

and produced in the manufacturing plant(s):

Shenzhen Pilot Guards Safety Technology Co. Limited (SG-23854)

No.9, Huafu Industrial Park, Huachang Road

Longhua District, Shenzhen City, Guangdong Province

P. R. China

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the

standard(s):

EN 14604:2005+AC:2008

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to

remain constant.

This certificate was first issued on **2022-07-26** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product

certification body.

Notified Body 0905

Certification Manager: Dipl.-Ing. Roland Heine Date Issue: 2022-07-26

Issue: 1

Signature:

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-220579

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-220579

The details and conditions of use for the Smoke Detector Alarm, placed on the market under the name or trade mark of:

Shenzhen Pilot Guards Safety Technology Co. Limited No.9, Huafu Industrial Park, Huachang Road Longhua District, Shenzhen City, Guangdong Province P. R. China

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (where applicable):

Products compliant with EN 14604:2005+AC:2008

Model	Manufacturing Location	Description
PA-437EN	SG-23854	Domestic Smoke Alarm
PA-443	SG-23854	Domestic Smoke Alarm (lid variant)

Batteries:

The PA-437EN & PA-443 Photoelectric Domestic Smoke Alarms are each powered and approved for use with the following 9VDC replaceable alkaline battery (1-year lifespan):

• Tcbest company Ultra Alkaline 6LR61

Conditions of use:

Suitable for indoor applications.

General Notes:

- 1. Evaluated under Intertek project number G103958475.
- **2.** The PA-437EN & PA-443 Photoelectric Smoke Alarms have not been approved for installation into leisure accommodation vehicles (LAVs).
- 3. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen